



Retail Food Establishment Inspection Report

Floyd County Health Department
Telephone: 812-948-4726

X678

Based on an inspection this day, the item(s) noted below identify violations of 410 IAC 7-24, Indiana Retail Food Establishment Sanitation Requirements. The time limit for correction of each violation is specified in the narrative portion of this report.

Establishment Name Dock's Seafood	Telephone Number () Establishment 844-2951 () Owner	Date of Inspection (mm/dd/yr) 4-1-19	ID # 18-211
Establishment Address (number and street, city, state, zip code) 1125 State St New Albany, IN 47150			
Owner Hubert Rockey	Purpose: 1. Routine 2. Follow-up 3. Complaint 4. Pre-Operational 5. Temporary 6. HACCP 7. Other (list)	Follow-up NO	Release Date Today
Owner's Address		Summary of Violations: C <input checked="" type="checkbox"/> NC 2 R <input checked="" type="checkbox"/>	
Person in Charge		Menu Type (See back of page) 1 2 3 <input checked="" type="checkbox"/> 4 5	
Responsible Person's E-mail			
Certified Food Handler Sandra Rockey			

• CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"

• VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRATIVE BELOW AS "R"

Section#	C/NC	R	Narrative	To Be Corrected By
			- Received complaint about moldy ceiling tiles, an exposed wires near ceiling fans. -	
430	NC		Observed 6 ceiling tiles in lobby to have water spots. - No mold observed.	3 weeks
310	NC		Observed build-up of dust on air intake vent and security lights in lobby.	1 week
			- Consider replacing wet tiles with non absorbant ceiling tiles to prevent frequent replacement.	
			- Observed wires near overhead fans. determined they were not a risk.	

Received by (name and title printed): William Simon Cook	Inspected by (name and title printed): Thomas Swider, EHS
Received by (signature): <i>William Simon</i>	Inspected by (signature): <i>Thomas Swider</i>
cc:	cc: